



Marine & Offshore

Certificate number: 40654/A0 BV

File number: ACI 1000/548/003

Product code: 5080H

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

TYPE APPROVAL CERTIFICATE

This certificate is issued to

MORGAN ADVANCED MATERIALS THERMAL CERAMICS

WIRRAL - UNITED KINGDOM

for the type of product

A60 CLASS DECKS

A-60 Steel Deck "FireMaster Marine Plus Blanket, 45mm x 64 kg/m³"

Requirements:

Bureau Veritas Rules for Classification of Ships, Part C, Chapter 4

SOLAS 74 Convention, as amended, Regulation II-2

IMO resolution MSC.307(88) -FTP Code 2010-

IMO MSC/Circ.1435

This certificate is issued to attest that Bureau Veritas Marine & Offshore did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 02 Jun 2026

For Bureau Veritas Marine & Offshore,

At BV LONDON, on 02 Jun 2021,

Spencer Yule



This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with Bureau Veritas Marine & Offshore. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of Bureau Veritas Marine & Offshore available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas Marine & Offshore for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

The electronic version is available at: <http://www.veristarm.com/veristarnb/jsp/viewPublicPdfTypepec.jsp?id=jkbqltzyem>

BV Mod. Ad.E 530 June 2017

This certificate consists of 3 page(s)

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION:

A-60 Steel Deck "FireMaster Marine Plus Blanket, 45mm x 64 kg/m³"

Structural deck insulated underneath with one layer of "FireMaster Marine Plus Blanket", 45 mm thick, density of 64 kg/m³.
Applied in between and around the stiffeners in strips of 600 mm width.
No packing is required in the stiffener cavities.

Fastening arrangement : steel pins / washers

Pins spacing :

- max 300 x 300 mm

- max 150 mm from "FireMaster Marine Plus Blanket" joints

2. DOCUMENTS AND DRAWINGS:

2.1 - Fire Protection System Information sheet N° FM 4.71 Rev 2 dated November 2013.

2.2 - As per Manufacturer's drawing N° MAMK-201511-A60-001 rev. 0 dated 05/11/2015.

3. TEST REPORTS:

Test report N° KOMERI-0402-15T3831 dated 26/02/2016, as per IMO 2010 FTP Code, Annex 1, Part 3, from KOMERI, Korea.

4. APPLICATION / LIMITATION:

4.1 - The following component(s) shall comply with the requirements of the relevant Bureau Veritas rules and be type approved:
- the insulating material "**FireMaster Marine Plus Blanket (64 kg/m³)**",
- any added surface finish material(s).

4.2- The fitting aboard to be the same as used for the test.

5. PRODUCTION SURVEY REQUIREMENTS:

5.1 - The **A-60 Class Deck "FireMaster Marine Plus Blanket, 64 kg/m³** are to be supplied by **Morgan Advanced Materials, Thermal Ceramics** in compliance with the type described in this certificate.

5.2 - This type of product is within the category HBV of Bureau Veritas Rule Note NR320 and as such does not require a BV product certificate.

5.3 - **Morgan Advanced Materials, Thermal Ceramics** has to make the necessary arrangements to have its works recognised by Bureau Veritas in compliance with the requirements of NR320 for HBV products.

5.4 - For information, **MORGAN ADVANCED MATERIALS THERMAL CERAMICS** has declared to Bureau Veritas the following production site(s):

MORGAN THERMAL CERAMICS KOREA
335 Nongon-ro
Nongong-eup, Dalseong-gun
Daegu, KOREA (REPUBLIC OF)

6. MARKING OF PRODUCT:

The product or packing is to be marked with manufacturer name, type, designation and fire-technical rating.

7. OTHERS:

7.1 - It is **Morgan Advanced Materials, Thermal Ceramics**'s responsibility to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.

7.2 - This certificate is based on the EC-Type Examination Certificate N°MEDB000001NR rev. 1 issued on 28/02/2017 by DNV-GL.

***** END OF CERTIFICATE *****