

TYPE APPROVAL CERTIFICATE

Certificate No:
TAF00000FF
Revision No:
1

This is to certify:

That the Class A Bulkhead

with type designation(s)
A-60 Steel Bulkhead - FireMaster XLS Blanket 60 mm x 64 kg/m3

Issued to
Thermal Ceramics UK Ltd
Wirral, Merseyside, United Kingdom

is found to comply with
DNV GL statutory interpretations DNVGL-SI-0364 – SOLAS interpretations
DNV GL rules for classification – Ships
DNV GL offshore standards

Application :

Approved for use as a vertical fire retarding division of class A-60.

General application: Fire hazard from either side

This certificate is recognized by Transport Canada.

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Issued at **Høvik** on **2021-06-04**

for **DNV**

This Certificate is valid until **2026-06-03**.

DNV local station: **Manchester**

Approval Engineer: **Helge Bjørnarå**

Sverre Olav Bergli
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

A-60 Steel Bulkhead - FireMaster XLS Blanket 60 mm x 64 kg/m³
composed of a structural steel bulkhead insulated with a single layer of 60 mm thick FireMaster XLS Blanket (manufactured by Thermal Ceramics with density 64 kg/m³) applied in between stiffeners and packed inside stiffeners and 25 mm thick FireMaster XLS Blanket (manufactured by Thermal Ceramics with density 64 kg/m³) applied around the stiffeners.

The blankets are held in place using mild steel pins (Ø 3 mm / typically 50 mm long) welded to the bulkhead with friction-fit mild steel washers. The pins are to be installed with a nominal spacing of 300 mm across the blankets and maximum 350 mm along the blankets, whereas pins at the joints between blankets shall have a nominal spacing of 300 mm from the blanket edge. Maximum pin distance to lengthways joint is 300 mm.

The installation is to be performed according to the manufacturers Fire Protection Systems Information, reference No. FM MS 01 PW and No. FM 4.112.

The products may be manufactured at the premises of:

- Thermal Ceramics de France S.A., Saint Marcelin en Forez, France.
- Thermal Ceramics Korea, Daegu, Korea.
- Grupo Industrial Morgan SA de CV, Mineral de La Reforma, Mexico.

Application/Limitation

Approved for use as a vertical fire retarding division of class A-60.

General application: Fire hazard from either side

Any surface materials used have to be approved for smoke and toxicity and low flame-spread characteristics (IMO 2010 FTP Code Parts 2 and 5) when required according to relevant rules.

Each product is to be supplied with its manual for installation and maintenance.

Type Approval documentation

Certification in accordance with Class Programme DNVGL-CP-0338, September 2018.

Test report No. KOMERI-0402-15T4083-1 dated 10 August 2016 from KOMERI, Busan, Korea.
Dwg. No. MAMK-20160416-A60-003 dated 18 April 2016 from manufacturer.

Thermal Ceramics Fire Protection Systems Information, reference No. FM MS 01 PW and No. FM 4.112, Rev. 1.

Tests carried out

Tested according to IMO 2010 FTP Code Part 3.

Marking of product

The product or packing is to be marked with name of manufacturer, type designation and fire technical rating.

Transport Canada Approval

Based on the procedures laid down in the Transport Canada Publication entitled "Approval Procedures for, Life Saving Equipment and Structural Fire Protection Products (TP 14612)", DNV confirms that the product/s listed in this certificate is/are in accordance with Transport Canada's requirements.

Periodical assessment

DNV's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNVGL-CP-0338, Section 4.